



**UOJZ.S789**  
**Control Units, System**

[Page Bottom](#)**Control Units, System**[See General Information for Control Units, System](#)**HONEYWELL SECURITY**

S789

SUITE 100  
2 CORPORATE CENTER DR  
PO BOX 9040  
MELVILLE, NY 11747 USA

Model	Control Unit System Type	Initiating Device Type(s)	Signaling Type(s)
<b>control unit</b>			
<b>9500, 9800, 9850, MX8000</b>	CS (RU)	A, M, SS, WF	DAC
<b>FA167OCT</b>	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, OT
	P (PPU)	A, M, SS, WF	DAC, OT
	CS (PPU)	A, M, SS, WF	DAC, OT
<b>FA170OCT</b>	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, OT
	P (PPU)	A, M, SS, WF	DAC, OT
	CS (PPU)	A, M, SS, WF	DAC, OT
<b>Vista-128FBP, Vista-128FBPN, Vista 250FBP (h)</b>	CS (PPU), L, P (PPU), RS (PPU)	A, M, SS, WF	DAC, NC, OT
<b>Vista-128FBPT</b>	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, OT
	P (PPU)	A, M, SS, WF	DAC, OT
	CS (PPU)	A, M, SS, WF	DAC, OT
<b>Vista-250FBPT, TYCMSM250, TYC250F</b>	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, OT
	P (PPU)	A, M, SS, WF	DAC, OT
	CS (PPU)	A, M, SS, WF	DAC, OT
<b>Vista-32FB(h)</b>	CS (PPU), P (PPU), RS (PPU)	A, M, SS, WF	DAC, MX, NC, OT
<b>Vista-32FBPT</b>	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, OT

	P (PPU)	A, M, SS, WF	DAC, OT
	CS (PPU)	A, M, SS, WF	DAC, OT
<b>Internet Receiver</b>			
<b>7810iR-ent (c)</b>	CS (RU), P (RU)	-	OT
<b>FA1670C(h)</b>	CS (PPU), L, P (PPU), RS (PPU)	A, M, SS, WF	DAC, NC, OT
<b>FA1700C(h)</b>	CS (PPU), L, P (PPU), RS (PPU)	A, M, SS, WF	DAC, NC, OT
<b>FOCUS 200 PLUS (b)</b>	CS, L, P, RS	A, M, SS, WF	DAC, NC, OT

**Control unit enclosures**, Model(s) COM-UL

**Control unit sub-assemblies**, Model(s) 472490 (5800ADT) RF Gateway (g)

CS (RU) - Central Station System (Supervising Station Receiving Unit)

A - Automatic Fire Alarm: thermostats, smoke detectors, etc.

M - Manual Fire Alarm: manually operated boxes

SS - Supervisory: gate valves, water-level switches, temperature switches, carbon monoxide alarm, residential fire alarm control units, etc.

WF - Waterflow Alarm: waterflow switches

DAC - Digital Alarm Communicator

L - Local System

March - March Time

NC - Noncoded, Steady, Temporal 3 Pattern, etc.

RS (PPU) - Remote Station System (Protected Premises Unit)

OT - Other Transmission Technologies

P (PPU) - Proprietary System (Protected Premises Unit)

CS (PPU) - Central Station System (Protected Premises Unit)

MX - Multiplex

P (RU) - Proprietary System (Supervising Station Receiving Unit)

CS - Central Station System

P - Proprietary System

RS - Remote Station System

(b) - FOCUS 200 PLUS Control Unit, consisting of Model SAFOC200-1, SAFOC200-2, SAFOC200-VE or SAF200PA Sub-Assembly Circuit Board and Model COM-UL Enclosure. For Remote Station fire alarm service the 472404 or 1451, 72 VA Transformer must be used. For central Station fire alarm service either the 472404 or 1451, 72 VA transformer may be used. The following accessories are also suitable for use with the FOCUS 200 PLUS control unit, 148320 Junction Box, 472402A (5140DLM) Backup DACT, 427368 SIM Gateway, 472490(5800ADT) RF Gateway, 471883 COPID and 472488 SIM (Sensor Interface Module).

(g) - For use with Model FOCUS 200 PLUS control units.

(h) - Requires additional equipment for OT Signaling

[Last Updated](#) on 2015-04-27

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".